

**BSOOB Transit RFP # 2023 504-1: Perimeter Security Fence and Gate System
Addendum 1 – May 15, 2023**

1. Will the driveway entrance gate require bollards?

The single slide 26' automatic entrance gate requires four 6" bollards to be located at each side of the gate. The bollards will stand a minimum of 44" from the ground.

2. Will the driveway entrance gate require a manual override?

The single slide 26' automatic entrance gate requires a manual override.

3. Is the fence project contractor required to install the power and communication conduit for the entrance gate?

The fence project contractor is not responsible for the power and communication conduit.

4. Will the fence require barbed wire?

The fence project does not require barbed wire.

5. Where will the pedestrian gate at the entrance of the property be located?

The pedestrian gate will be located on the left side of the entrance, (facing the building - SW corner), of the driveway.

6. Where will the pedestrian gate by the building be located?

The pedestrian gate by the building will be located near the dumpster, on the left side of parking area in front of the building.