



Bus Wash Mechanical Room Addition

RFP #2024-215-1

Date of Issue: February 15, 2024

Due: March 15, 2024

Addendum RFP #2024-215-B, issued 3/7/2024, Clarification of products

1. The question came up on framing to the slab instead of pouring concrete for the front corner and each side of the overhead door.

Concrete or CMU block as it adds protection from the weather and impacts during snow removal, etc.

2. Can this be done and metal or wood?

All framing should metal, along with roof sheeting, liner panel and siding.