

# Transit

Biddeford | Saco | Old Orchard Beach

April 4, 2025

Addendum 1

-Are you going to provide more details on the design specs (ie canopy size, DEF system, FuelMaster, Monitoring System, Dispensers, etc)?

The size of the fuel mat that the existing pumps are located on are roughly 38 ft long by 28 ft wide. The canopy can be up to 20 ft long by 15 wide or a size equivalent to the 4:3 Length to width ratio but does not need to cover the entire fuel mat.

I am attaching pictures of the DEF system, FuelMaster and Dispensers that we currently have in place. Dispensers need to be of an industry standard quality with a high flowrate with a washable pump filter and meter filter that can also be replaced. The dispensers must have a hose retraction system.

Fuel Master System



# Transit

Biddeford | Saco | Old Orchard Beach

DEF (6'x 6' approximately)



Dispensers (Tokheim from 1979)



The DEF system does not need to be replaced or put under the ground so we will be removing the need of this in the RFP and you may price the project without the DEF system in it.

# Transit

Biddeford | Saco | Old Orchard Beach



This is the current system and we do not need fire suppression but we with need the canopy to have lights and a drain.

Trahmel Milashouskas

Grant & Procurement Coordinator